

- 1 Q. Produce the draft opacity limits referred to in the first paragraph on page 4 of
2 the report entitled Holyrood Thermal Generating Station Air Emission Control
3 Assessment produced in response to PUB 8-NLH.
4
5
6 A. The “draft opacity limits” have since been included in Schedule D to the *Air*
7 *Pollution Control Regulations, 2004*, and are as follows:

Schedule D

Administrative Penalties for Opacity Exceedences

New Fire	Best Available Control Technology	Time Frame	Opacity	1st Exceedence	Subsequent Exceedences
NO	NO	1 Hour	>20% , # 25%	\$ 0	\$ 5
NO	NO	1 Hour	>25% , # 30%	\$ 5	\$ 10
NO	NO	1 Hour	>30%	\$ 10	\$ 15
YES	NO	30 Minutes	>20% , # 40%	\$ 0	\$ 5
YES	NO	30 Minutes	>40% , # 50%	\$ 5	\$ 10
YES	NO	30 Minutes	>50%	\$ 10	\$ 15