

1    Q.    If the change to 1% sulphur content does not fully achieve the desired  
2           results, what plan does NLH have for future improvements to the PM<sub>10</sub>, the  
3           SO<sub>2</sub> emissions and the opacity of the Holyrood Thermal Generating Station?  
4  
5

6    A.    If, after an acceptable period of emissions monitoring, the change to 1%  
7           sulphur does not fully achieve the desired result, then it would be necessary  
8           to evaluate the degree of non-compliance to determine what appropriate  
9           further action and improvements to the PM<sub>10</sub>, the SO<sub>2</sub> emissions and the  
10          opacity of the Holyrood Thermal Generating Station may be required to  
11          achieve compliance.