

1 Q. With reference to the Technical Conference on Project B-14 Holyrood  
2 Condition Assessment, has there been any assessment by Hydro,  
3 preliminary or otherwise, to distinguish between which Holyrood components  
4 it is proposed be subjected to an EPRI Level 2 assessment and those it is  
5 proposed be subjected to EPRI Level 3 assessment?  
6  
7

8 A. There has been no discussion to determine which components will be  
9 subjected to the three EPRI examination levels. This will be determined for  
10 most components prior to beginning the project and for some as the project  
11 progresses and more data has been accumulated.