

1 Q. With reference to the Technical Conference on Project B-14 Holyrood  
2 Condition Assessment, is it being proposed that major equipment which has  
3 been or will have been recently replaced (for instance, Units 1 and 2 stack  
4 liners in 2002/05 and Unit 2 high temperature superheater in 2006/07) will  
5 need to be assessed at EPRI Level 2 or EPRI Level 3?  
6  
7

8 A. It will not be necessary to subject any equipment which has been recently  
9 replaced, or is scheduled for replacement, to detailed examination. Recently  
10 replaced equipment will be identified, the service life of the original  
11 equipment noted and changes in design, materials, operation or  
12 maintenance of the replacement identified so that the expected service life of  
13 the replacement can be predicted.