

1 **B-97 Battery Replacements, \$485,000**

2 Q. How often is capacity testing performed on battery banks?

3

4

5 A. Capacity testing is performed at five year intervals for flooded cell battery
6 banks, at three year intervals for non-flooded (Valve Regulated Lead Acid)
7 battery banks and more frequently when accelerated deterioration is
8 suspected.