

1    **B-14 Holyrood Condition Assessment, \$3,334,900**

2    Q.    What is the time line for the completion of the various components of the  
3           Holyrood Condition Assessment?

4

5

6    A.    The precise timing for various components of the study cannot be  
7           determined until the 2007 unit outage schedule for Holyrood has been  
8           established. Unit outages are required to perform equipment inspections. It  
9           is intended that all study components will be completed by the end of the  
10          calendar year.