

1    Q.    Provide a detailed explanation of the scope of work proposed in this project,  
2           setting out the type of assessment that is going to be performed on the major  
3           components of each of the generating units and the costs that will be  
4           associated with each, setting out whether an EPRI Level 1, 2 or 3 will be  
5           conducted.

6

7

8    A.    The scope of the assessment portion of this study will be the assessment of  
9           all components within the Holyrood Generating Station property line, at the  
10          appropriate EPRI level of investigation. For many components, the decision  
11          of which level of assessment to apply will be made when the contract  
12          document is prepared for tender. The level of study for the balance of the  
13          components will be identified as the work progresses and knowledge about  
14          the condition of similar components becomes available. Generally speaking,  
15          the greater the effect a component has on the ability of a unit to operate at  
16          rated capacity, the higher the level of assessment which will be applied.