

1 Q. Provide a timeline for the completion of any resulting changes to the plant.

2

3

4 A. It is not possible to produce timelines for completion of the changes at this
5 time. From receipt of approval to proceed, construction of a precipitator could
6 probably be completed within three years while construction of a combined
7 cycle unit would take about three and one half years. Implementation of life
8 extension improvements would be scheduled over many years as
9 components reached the ends of their useful lives. Timelines for each of the
10 options being investigated will be prepared as part of the study.