

1 **B-16 Upgrade Unit NO. 3 Turbine/Generator, \$1,654,300**

2 Q. Has NLH undertaken a cost benefit analysis of similar maintenance options
3 for Units 1 and 2 at Holyrood? If so, please explain.

4

5

6 A. It is not necessary to perform an analysis on Units 1 and 2. An assessment
7 of the three units indicated that only Unit 3 required these upgrades to enable
8 the outage intervals to be extended from six to nine years.