

1 **B-16 Upgrade Unit NO. 3 Turbine/Generator, \$1,654,300**

2 Q. Does NLH intend to similarly change the overhaul schedules of Units 1 and 2  
3 at Holyrood?

4

5

6 A. Units 1 and 2 at Holyrood have already been placed on the same nine-year  
7 overhaul schedule.