

1    **B-23 Replace Fuel Piping, \$529,800**

2    Q.    Are similar underground fuel pipes being used at other sites? If so, please  
3        provide details including ages and condition.

4

5

6    A.    Hydro does not have a similar installation at another site. Hydro has two  
7        other gas turbine sites, at Happy Valley Goose Bay and at the Holyrood  
8        Generating Station. The Happy Valley Goose Bay site has a section of  
9        underground fuel pipe but it has secondary containment in the form of a  
10       double walled pipe with a leak detector installed in the interstitial space. That  
11       installation is only 15 years old. The Holyrood site has above ground piping.  
12       The existing 30-year-old Stephenville arrangement has only single wall pipe,  
13       which was accepted practice when it was installed.