

1 **B-29 Reliability Upgrades-Frequency Converter, \$1,320,200**

2 Q. Provide a breakdown of the costs of the components of this project.

3

4

5 A. The breakdown of costs for this project are:

6 Rewind 50 HZ Machine Rotor \$600,200

7 Installation of oil spill containment & fire protection \$412,000

8 General upgrades of wall trusses and doors \$ 59,000

9 Replacement of auto-synchronizer \$ 20,000

10 Replacement of lube oil pump \$ 7,000

11 Replacement of 69 kV entrance bushings \$222,000

12

13 Total \$1,320,200