

1 **B-58 Upgrade Distribution Feeders, \$1,383,200**

2 Q. For each year from 2001 to 2006F provide SAIFI, SAIDI and SARI figure for
 3 the Harbour Breton System, the Farewell Head System, the Rocky Harbour
 4 System and the St. Anthony System, along with the overall utility average
 5 and the regional average for those years.

6
 7

8 A. Attached is the SAIFI, SAIDI and CAIDI, for the Farewell Head, Harbour
 9 Breton, Rocky Harbour and St. Anthony systems, along with the overall utility
 10 average and the regional average (2001 - 2006).

SAIFI* *combined for planned and unplanned outages

Year	Corporate	Central Interconnected	Northern Interconnected	Barchoix Harbour Breton (L4)
2001	7.47	6.96	4.69	6.75
2002	9.44	7.20	7.11	6.92
2003	7.88	7.42	6.66	11.67
2004	5.90	4.73	4.04	4.48
2005	5.84	3.35	4.62	5.98
2006*	3.33	1.67	2.89	2.35
Average	6.64	5.22	5.00	6.36

SAIFI*

Year	Farewell Head		Rocky Harbour		St Anthony	
	L2	L3	L1	L2	L1	L2
2001	0.25	1.37	6.43	3.93	7.28	3.14
2002	3.60	3.89	8.62	7.04	13.59	8.57
2003	5.12	6.31	10.05	9.81	6.74	2.53
2004	5.27	6.62	0.03	1.23	3.68	4.84
2005	9.16	5.16	2.35	3.09	4.38	2.06
2006*	2.08	2.19	1.01	1.04	2.09	2.17
Average	5.05	4.83	4.41	4.44	6.10	4.03

SAIDI* *combined for planned and unplanned outages

Year	Corporate	Central Interconnected	Northern Interconnected	Barchoix Harbour Breton (L4)
2001	10.17	16.13	5.88	16.60
2002	13.63	17.18	10.77	18.41
2003	11.91	17.94	10.78	24.35
2004	11.17	11.98	7.84	7.61
2005	8.80	7.53	8.83	8.74
2006*	4.59	4.30	3.56	4.43
Average	10.04	12.51	7.94	13.36

SAIDI*

Year	Farewell Head		Rocky Harbour		St Anthony	
	L2	L3	L1	L2	L1	L2
2001	2.08	4.77	4.98	4.17	9.52	0.65
2002	8.56	11.52	10.18	8.77	38.55	9.68
2003	29.71	51.28	9.65	9.94	15.26	1.27
2004	49.17	54.22	0.03	2.52	5.16	5.69
2005	11.17	19.14	3.53	4.68	2.99	0.81
2006*	15.02	27.14	0.75	0.7	0.77	0.53
Average	22.73	32.66	4.83	5.32	12.55	3.60

CAIDI* *combined for planned and unplanned outages

Year	Corporate	Central Interconnected	Northern Interconnected	Barchoix Harbour Breton (L4)
2001	1.36	2.32	1.25	2.46
2002	1.44	2.38	1.51	2.66
2003	1.51	2.42	1.62	2.09
2004	1.89	2.53	1.94	1.70
2005	1.51	2.25	1.91	1.46
2006*	1.38	2.57	1.23	1.89
Average	1.52	2.41	1.58	2.04

CAIDI*

Year	Farewell Head		Rocky Harbour		St Anthony	
	L2	L3	L1	L2	L1	L2
2001	8.32	3.48	0.77	1.06	1.31	0.21
2002	2.38	2.96	1.18	1.25	2.84	1.13
2003	5.80	8.13	0.96	1.01	2.26	0.50
2004	9.33	8.19	1.00	2.05	1.40	1.18
2005	1.22	3.71	1.50	1.51	0.68	0.39
2006*	7.22	12.39	0.74	0.67	0.37	0.24
Average	5.19	7.08	1.03	1.26	1.48	0.61

1 SARI is used for transmission systems only and in distribution systems, a
2 measure called CAIDI is used.

3

4 CAIDI is the Customer Average Interruption Duration Index and is calculated
5 by dividing the SAIDI by SAIFI

6

7 * 2006 data up to August 25, 2006