

1 **B-8 Station Service Control Replacement, \$105,200**

2 Q. Has the loss of PLC control become less likely as a result of the upgrades
3 outlined in the Telecommunications Plan – Revised August 2002?

4

5

6 A. The two devices are unrelated. A PLC as used for the Station Service is a
7 Programmable Logic Controller. In Telecommunications, PLC is Power Line
8 Carrier.