

1 **Q. In reference to Schedule “B”, page 13 of 82, - Pen Stock Replacement Lockston,**  
2 **please provide all inspection, engineering reports and studies completed to justify**  
3 **the project. Please provide particular data to justify moving up the project for**  
4 **replacement from 2006.**

5  
6 A. Please refer to the Company’s response to Request for Information PUB 3.2, Attachments  
7 A through F, for copies of all inspection, engineering reports and studies completed to  
8 justify this project.  
9

10 Attachment E, a report by Newlab Engineering, identifies penstock replacement as a top  
11 priority. As a result of the consultant’s recommendation, the Company conducted an in-  
12 house inspection and re-prioritization of the wooden penstocks scheduled for replacement  
13 within the next 5 years. On the basis of this report, the Company’s inspection and 2002  
14 maintenance experience, the replacement of the Lockston penstock was advanced from  
15 2006 to 2003.