

1 In reference to Schedule “B”, page 15 of 82, the purchase of portable diesel generation at a
2 project cost of \$1,500,000:

3
4 **Q.** Noting that diesel number two is rated at 670 kW and the diesel to be purchased is
5 rated at 2.5 MW, please advise why a 2.5 MW rating is now required. Please
6 provide a comparable list of prices for portable diesel generating units giving
7 ratings less than 2.5 MW. Please provide an analysis of the project cost, including
8 material supplies, labour, engineering, project management and the like, justifying
9 the project cost of \$1,500,000.

10
11 **A.** Please refer to the Company’s response to the Public Utilities Board Request For
12 Information PUB 4.1, Attachment A, for the report analyzing the sizing, unit location,
13 and costs associated with this project. The project costs include \$60,000 for labour and
14 \$1,440,000 for non-labour for a total of \$1,500,000.