

1 **Q. Please provide the cost anticipated for the decommissioning of the 2.5 MW diesel**
2 **plant in St. John's**

3
4 A. The decommissioning costs of the 2.5 MW diesel plant in St. John's has been estimated
5 at approximately \$250,000. This includes costs for equipment removal, demolition, site
6 work, and environmental testing and remediation.