

1 **Q. Please provide a schedule of the usage of the 2.5 MW diesel plant in St. John's for**  
2 **the last seven years, including times and dates.**

3  
4 A. The table below provides a summary of the usage for the past seven years for the St.  
5 John's diesel plant. The majority of the start-ups were for testing purposes. The May  
6 25<sup>th</sup> to 26<sup>th</sup>, 1998 usage was to pick up load on a feeder from the St. John's Main  
7 Substation during scheduled capital work.  
8

Date	Time
January 2 <sup>nd</sup> , 1996	50 minutes
March 2 <sup>nd</sup> , 1996	20 minutes
June 20 <sup>th</sup> , 1996	25 minutes
January 21 <sup>st</sup> , 1997	57 minutes
February 4 <sup>th</sup> , 1997	56 minutes
March 24 <sup>th</sup> , 1997	65 minutes
May 20 <sup>th</sup> , 1998	70 minutes
May 25 <sup>th</sup> , 1998	610 minutes
May 26 <sup>th</sup> , 1998	600 minutes
November 18 <sup>th</sup> , 1999	5 minutes
December 21 <sup>st</sup> , 1999	7 minutes
December 22 <sup>nd</sup> , 1999	51 minutes

9