

1 In reference to Schedule “B”, page 20 of 82 – replacement and spare substation equipment
2 – at a project cost of \$1,107,000:

3
4 Q. Please provide the number of batteries and chargers to be replaced and the cost for
5 each.

6
7 A. Table 1 below identifies the number of battery banks and battery chargers to be replaced
8 under this project and the budgeted cost.
9

Table 1 Budgeted Cost to Replace Batteries and Battery Chargers				
Equipment	Quantity	Total Labour	Total Non-Labour	Total Cost
125V Battery Bank	1	\$5,600	\$12,700	\$18,300
48V Battery Bank	5	\$4,400	\$12,700	\$17,100
Chargers	4	\$7,000	\$17,600	\$24,600