

In reference to Schedule “B”, page 22 of 82 – Reliability and Power Quality Improvements, at a project cost of \$198,000:

Q. Please provide the material and labour costs and any other associated costs to install a re-closer and equipment for the additional feeder at Collier’s substation.

A. Installation of the reclosers and associated equipment at Colliers Substation is estimated to cost \$18,000 for labour and \$52,000 for non-labour items for a total of \$70,000.