

1 **In reference to Schedule “B”, page 22 of 82 – Reliability and Power Quality Improvements,**
2 **at a project cost of \$198,000:**

3
4 **Q. Please provide the material and costs to install motor operator and switchers from**
5 **Holyrood to Bay Roberts.**

6
7 A. Installation of a motor operator on switchers for transmission line 39L is estimated to cost
8 \$41,000 for labour and \$59,000 for non-labour items for a total of \$100,000.