

In reference to Schedule “B”, page 23 of 82 – Substation Protection and Monitoring Improvements, at a project cost of \$425,000:

**Q. Please provide the specific costs for materials and labour to replace protective relays at Greenhill, Laurentian and Salt Pond substations.**

**A.** This project involves the replacement of protective relays on 302L (Greenhill to Laurentian) and 305L (Salt Pond to Laurentian). Table 1 below provides an estimate of the labour and non-labour costs for each transmission line.

**Table 1**  
**Substation Protection and Monitoring Improvements**  
**Replace Protective Relays**  
**Greenhill, Laurentian and Salt Pond Substations**

<b>Transmission Line</b>	<b>Labour</b>	<b>Non-Labour</b>	<b>Total</b>
302L	\$27,300	\$26,200	\$53,500
305L	27,300	26,200	53,500
<b>Total</b>	<b>\$54,600</b>	<b>\$52,400</b>	<b>\$107,000</b>