

1 In reference to Schedule “B”, page 23 of 82 – Substation Protection and Monitoring  
2 Improvements, at a project cost of \$425,000:

3  
4 Q. In reference to the two projects under \$50,000 at page 28 of 82, please provide a  
5 breakdown as to the materials and labour costs for the two projects at Blaketown  
6 and at the Gallant Street substation.

7  
8 A. Table 1 below provides an estimate of the labour and non-labour costs associated with the  
9 two projects less than \$50,000. One project involves the installation of reclosing relays at  
10 Blaketown Substation and the second project involves the installation of an under-  
11 frequency relay at the Gallant Street Substation.  
12  
13

<b>Table 1</b> <b>Substation Protection and Monitoring Improvements</b> <b>Projects Less Than \$50,000</b>			
<b>Substation</b>	<b>Labour</b>	<b>Non-Labour</b>	<b>Total</b>
Blaketown	\$20,000	\$15,000	\$35,000
Gallant Street	10,000	10,000	20,000
<b>Total</b>	<b>\$30,000</b>	<b>\$25,000</b>	<b>\$55,000</b>