

1 In reference to Schedule “B”, page 29 of 82 – Chamberlains - Transformer – project cost  
2 \$1,250,000:

3  
4 **Q. Please provide the system average interruption frequency index (SAIFI) and the**  
5 **system average interruption duration index (SAIDI) in hours for Chamberlains,**  
6 **Manuels and the Topsail areas of Conception Bay South for the periods 1997 to the**  
7 **present.**

8  
9 **A.** The table below provides SAIDI and SAIFI statistics for customers supplied by the  
10 Company’s Chamberlains Substation:  
11

<b>Table 1</b> <b>SAIDI/SAIFI Statistics</b> <b>Chamberlains Substation</b>		
<b>Year</b>	<b>SAIDI (hours)</b>	<b>SAIFI (interruptions)</b>
1997	5.42	2.97
1998	6.31	8.19
1999	12.84	4.18
2000	1.49	2.07
2001	1.74	2.81