

1 **In reference to Schedule “B”, page 29 of 82 – Chamberlains - Transformer – project cost**  
2 **\$1,250,000:**

3  
4 **Q. Under project justification it is stated, “the peak load at the substation exceeds the**  
5 **nameplate capacity of the substation transformer”. When did this happen.**

6  
7 A. The existing transformer is rated at 25 MVA. In 2001, the peak load at the Chamberlains  
8 substation was 25.1 MVA.