

In reference to Schedule “B”, page 31 of 82 – Rebuild Transmission Lines – at a project cost of \$4,129,000:

Q. Advise as to when conductor 301L was last replaced.

A. The conductor on 301L, which was installed when these portions of the line were constructed in 1959 and 1966, have never been replaced.