at a project cost of \$500,000:

1

Q. Please provide the system average interruption duration index (SAIDI) in hours for the Old Perlican/New Chelsea and the Port Aux Basques/Rose Blanche areas from 1995 to the present.

In reference to Schedule "B", page 33 of 82 and the transmission system engineering study

SAIDI statistics for customers served by the Old Perlican and New Chelsea substations A. for the years 1995 to 2001 are presented in Table 1 below:

Table 1 SAIDI (hours)									
Substation	1995	1996	1997	1998	1999	2000	2001	2002*	Total
New Chelsea	4.29	8.02	8.85	11.29	3.70	9.87	6.08	10.40	62.50
Old Perlican	27.82	17.50	19.56	42.51	10.00	7.43	7.34	9.80	141.96
Total Area	19.58	14.18	15.81	31.59	7.80	8.28	6.90	10.01	114.15

SAIDI statistics for customers in the Port Aux Basques area (served by the Doyles, Grand

Bay, Port Aux Basques and Long Lake substations) for the years 1995 to 2001 are

11 12

13 14

15

16

Table 2 SAIDI (hours)									
Substation	1995	1996	1997	1998	1999	2000	2001	2002*	Total
Doyles	2.95	1.41	6.28	10.89	9.50	25.77	9.68	12.24	78.72
Grand Bay	6.84	5.13	6.73	8.01	6.51	9.96	6.39	5.65	55.22
PAB	10.82	7.23	7.92	7.56	7.07	29.79	5.18	2.64	78.21
Long Lake	18.76	7.98	17.66	35.17	32.87	21.03	5.13	4.94	143.54
<b>Total Area</b>	9.24	5.20	9.16	14.28	12.93	22.42	6.77	6.61	86.61

17 18 presented in Table 2 below:

<sup>\*</sup> Year to date.