

1 **In reference to Schedule “B”, page 46 of 82 – Trunk Feeders Rebuild Distribution Lines, at**  
2 **a project cost of \$3,504,000, please provide the following:**

3  
4 **Q. Under the project “Insulator Replacement – Various Feeders”, please advise as to**  
5 **when the insulators were previously replaced and the warranties that are in place in**  
6 **reference to these insulators.**

7  
8 A. The insulators being replaced on these feeders are the original insulators that were  
9 installed in the 1970s. There are no warranties covering these insulators.