

**In reference to Schedule “B”, page 52 of 82 – Trunk Feeders Improved Distribution System Protection / Operation:**

**Q. Please provide the SAIFI and SAIDI statistics for the last five years and the geographic areas which are covered by these projects.**

A. ‘Improved Distribution System Protection / Operation’ includes the items ‘install current limiting fuses’, ‘install disconnects on unfused taps’, ‘install cutouts – fuse co-ordination’, ‘install lightning arrestor’s, ‘offload feeders / taps and install switches’, and ‘sectionalizing for PAB Gas Turbine’.

With the exception of ‘sectionalizing for PAB Gas Turbine’, the remainder of the items are not targeted on individual feeders but are established on an area basis. There is a recognition of the general areas where these items are required to be done, but the exact substations or feeders to which these will apply has not yet been determined.

The SAIDI and SAIFI statistics for Grand Bay Substation, which services the Port Aux Basques Gas Turbine feeders can be referenced in CA-17(g).