

**In reference to Schedule “B”, page 64 of 82 – Substation Telephone Circuit Protection, project cost \$141,000:**

**Q. In reference to extending and increasing the diameter of the conduit containing Aliant Telecom’s incoming cable, please advise if these charges would be to the account of Aliant Telecom.**

**A.** Newfoundland Power must ensure that personnel working on communications equipment in the substation are protected from electric shock. As a result, Newfoundland Power is obligated to bear the cost of these installations. These costs will not be charged to Aliant Telecom.