

**Q. In the 2000 Capital Budget approval was granted for a distribution reliability initiative – trunk feeders (Schedule B, page 19 of 78). On page 20 of 78, the Company provided a table for each of the seven distribution feeders included in the project. Please provide a similar table for each of the seven distribution feeders, including the year 2001 and to date.**

**A.** Table 1 provides the average annual SAIDI and SAIFI statistics for the seven distribution feeders that were included in the 2000 distribution reliability initiative project for the periods January - December 2001 and January - August 2002. The SAIDI and SAIFI statistics in Table 1 exclude planned interruptions and interruptions due to loss of supply.

<b>Table 1</b> <b>Selected SAIFI and SAIDI Statistics</b> <b>January 2001 to August 2002</b>				
Feeder	January – December 2001		January – August 2002	
	SAIFI (Interruptions)	SAIDI (Hours)	SAIFI (Interruptions)	SAIDI (Hours)
Blaketown (BLK-02)	0.38	0.84	1.15	0.65
Old Perlican (OPL-02)	2.26	1.95	0.24	0.29
Bay L' Argent (BLA-01)	4.21	12.33	0.31	0.87
Laurentian (LAU-02)	9.50	30.05	2.14	1.12
Robinsons (ROB-01)	3.33	3.01	2.10	1.33
Doyles (DOY-01)	1.47	3.03	1.61	1.93
Abraham's Cove (ABC-02)	0.27	0.37	1.22	1.38