

1 **Thermal Plants Facility Rehabilitation (\$1,561,000)**

2
3 **Q. What spares were initially purchased for the governor and air intake structure of**
4 **the Port aux Basques gas turbine? Provide details on the spare parts currently in**
5 **inventory.**

6
7 A. Newfoundland Power originally acquired the Port Aux Basques (mobile) gas turbine in
8 1976. Any spare parts that were acquired with the unit at that time for the governor and
9 air intake structure have been consumed in the intervening years. Presently, the
10 Company has the following spare parts on hand for this unit's Woodward governor
11 system:
12

Part Number	Description
8271-070	High/Low Single Selector
8270-805	2301 Speed Sensor
8270-768	2301 Amplifier
8270-709	2301 Speed Sensor
8270-122	2301 Power Supply
8270-440	2301 Load Sensor

13
14 The Company does not presently have any spare parts on hand for the air intake structure.