

Trunk Feeders – Distribution Reliability Initiative (\$1,078,000)

Q. On page 51 of Schedule B, it is stated that planned outages and loss of supply from Hydro were excluded from the SAIFI and SAIDI statistics provided. Were loss of supply caused by Newfoundland Power's transmission and substation equipment also excluded? If not, provide the SAIFI and SAIDI values with all outages removed that are not caused by distribution feeder problems.

A. The SAIFI and SAIDI statistics provided on page 51 of Schedule B include only unplanned distribution caused outages and do not include outages due to 'loss of supply caused by Newfoundland Power's transmission and substation equipment'.