

SEAL COVE
OPERATOR'S DAM SAFETY INSPECTION
CHECKLIST

White Hill Pond Dam (Forebay)

Date: Feb. 18/2000

Water Level:	7.2'
Weather:	Sunny and cold
Upstream Slope:	OK
Crest:	OK N/C
Downstream Slope:	N/C
Sluice Gate:	OK
Gabions:	OK
Measurement of seepage (include picture):	
Spillway concrete:	OK
Abutments:	OK
Gabion Mat:	OK
Downstream Channel:	OK
Comments:	Crest needs filling in plus downstream slope