

**PUB 2.0**

**(RE: p. 11 & 12 of 82)      Thermal Plants Facility Rehabilitation (\$1,561,000)**

**PUB 2.4**

**Q.      What is the normal expected remaining life of the Greenhill gas turbine?**

A.      In its current role as an emergency generator, the Greenhill unit is operated infrequently, resulting in lower than normal wear and tear. With regular inspections and maintenance, and prudent capital investment, the Company estimates that the unit will provide reliable backup generation for in excess of 15 years.