

LOCKSTON
OPERATOR'S DAM SAFETY INSPECTION
CHECKLIST

Penstock

Date:Nov 19-01

Weather:	<u>Sunny</u>
Alignment:	<u>Sagging in places</u>
Bed:	<u>Washed out in places</u>
Drainage Ditches:	<u>Poor Drainage</u>
Culverts:	<u>Needs culvert</u>
Cradles:	<u>Needs repair</u>
Bands:	<u>Needs repair</u>
Woodstaves:	<u>Needs repair</u>
Steel Bifurcation:	<u>OK</u>
Concrete Supports:	<u>Needs repair</u>
Comments:	<u></u>