

1 **PUB 9.0**  
2 **(RE: p. 29 & 30 of 82) Chamberlains Add 66/12.5 kV Transformer (\$1,250,000)**  
3

4 **PUB 9.1**  
5

6 **Q. Has the Company undertaken a review of the plant available in the area of**  
7 **Chamberlains Substation with a view to meeting future growth? Is so, please**  
8 **provide a copy of the report.**  
9

10 A. The Company has not completed a formal review of the plant available in the area of the  
11 Chamberlains Substation. However, projections of load growth and future demand for all  
12 parts of the distribution system are developed as part of the Company's ongoing capital  
13 budgeting process. This has shown that load continues to grow at the Chamberlains and  
14 Kelligrews Substations.  
15

16 There are currently two feeders originating at the Chamberlains Substation. These are  
17 adequate for the existing load. Based on current forecasts of customer growth, the  
18 Company plans to undertake a review in 2004 to determine the best course of action to  
19 address the combined load growth at the Chamberlains and Kelligrews Substations.