

1 **Q. Provide for the years 1998 to 2001, and for the year to date for 2002, broken down**
 2 **by region and in total, the net Newfoundland Power SAIFI and SAIDI figures**
 3 **excluding any outages that can be attributed to Newfoundland & Labrador Hydro**
 4 **or to Acts of God (including storms).**

5
 6 A. Table 1 below provides Newfoundland Power SAIFI and SAIDI statistics by geographic
 7 area for each of the four years 1998 to 2001 and also for 2002 year to date (September).
 8 These statistics exclude both scheduled and unscheduled outages attributed to
 9 Newfoundland & Labrador Hydro.

10
 11 The statistics have not been revised to exclude Acts of God (including storms) as such
 12 events are not specifically identified in the Company's outage database and the
 13 identification of this type of outage after the fact would be highly subjective.

14
 15 The most significant storm event to influence these statistics over this period occurred in
 16 April 1999 over the St. John's, Avalon and Burin areas.

17
 18

Table 1						
SAIFI/SAIDI by Geographic Area: 1998 to 2002						
Area	Measure	Year				
		1998	1999	2000	2001	2002*
St. John's	SAIFI	2.41	2.79	3.11	2.56	1.36
	SAIDI	2.27	6.89	4.79	1.84	1.47
Avalon	SAIFI	3.37	5.00	3.67	3.48	1.79
	SAIDI	5.95	15.79	4.12	3.71	2.45
Burin	SAIFI	5.88	6.22	7.45	4.32	8.02
	SAIDI	13.57	9.82	10.98	8.02	8.52
Bonavista	SAIFI	4.20	6.41	3.66	3.62	6.12
	SAIDI	6.59	5.79	3.50	4.95	9.67
Gander	SAIFI	4.60	5.88	5.69	2.78	4.76
	SAIDI	7.14	12.49	7.76	4.16	6.30
Grand Falls	SAIFI	1.58	5.38	5.43	3.37	2.43
	SAID	2.20	9.56	6.74	5.10	3.78
Corner Brook	SAIFI	3.17	5.66	3.68	1.78	2.33
	SAIDI	3.97	5.38	3.17	2.03	2.57
Stephenville	SAIFI	4.60	16.05	5.46	3.95	3.08
	SAIDI	10.62	13.64	6.58	5.34	5.63

19
 20 * January to September 2002.
 21