

**Rattling Brook Rewind Generator G1, Volume 2, Appendix 1, page 3 (\$407,000)**

**Q. Please explain if the old coils will be reused and clarify whether it is the coils or the stator that will be shipped for refurbishing.**

A. The generator is a vertical unit with formed coil construction that cannot be economically reused. The stator winding (coils) will not be shipped for refurbishing. A complete set of new coils and winding kit will be fabricated by a supplier and shipped to site for installation.