

1 **New Chelsea Hydro Plant Refurbishment, Schedule B, page 12-13 (\$3,973,000)**

2

3 **Q. Have there been plant outages caused by the New Chelsea hydro plant protection**
4 **and control equipment in the last 5 years? If so, how many?**

5

6 **A.** Yes, there have been 92 plant outages (trips and lockouts combined) related to protection
7 and control equipment operation over the past five years (May 1998 to August 2003).