

**2.5 MW Standby Portable Diesel, Schedule B, pages 14-15 (\$1,700,000)**

**Q. Please provide a table showing the use of Newfoundland Power's previous two portable generators over the past 5 years, indicating for each occasion the reason for its use and the amount of energy generated.**

**A.** Table 1 provides a summary of the usage for portable Diesel # 1 for the period 1998 to 2002 inclusive, including reasons for use. Table 2 provides a summary of the usage for portable Diesel # 2 for the period 1998 to 2002 inclusive, including reasons for use.

<b>Table 1</b> <b>Schedule of Usage of Portable Diesel Number 1</b>			
<b>No.</b>	<b>Date</b>	<b>Energy Generated (kWh)</b>	<b>Reason for Use</b>
1	January 28, 1998	360	Test Run
2	March 13, 1998	330	Test Run
3	April 21, 1998	380	Test Run
4	May 28, 1998	380	Test Run
5	June 12, 1998	1,280	Scheduled Run for NF Hydro
6	July 28, 1998	5,310	Scheduled Run for NF Hydro
7	July 29, 1998	1,960	Scheduled Run for NF Hydro
8	July 30, 1998	3,070	Scheduled Run for NF Hydro
9	August 28, 1998	320	Test Run
10	September 30, 1998	290	Test Run
11	December 18, 1998	380	Test Run
12	January 26, 1999	300	Test Run
13	February 24, 1999	320	Test Run
14	March 31, 1999	590	Test Run
15	April 28, 1999	400	Test Run
16	May 28, 1999	400	Test Run
17	July 27, 1999	4,990	Scheduled Run for NF Hydro
18	July 28, 1999	4,370	Scheduled Run for NF Hydro
19	July 29, 1999	4,370	Scheduled Run for NF Hydro
20	July 30, 1999	3,740	Scheduled Run for NF Hydro
21	August 31, 1999	900	Scheduled Run for NF Hydro
22	September 8, 1999	5,640	Scheduled Run for NF Hydro
23	October 22, 1999	1,470	Unscheduled Outage - NF Hydro
24	November 29, 1999	260	Test Run
25	December 29, 1999	430	Test Run
26	January 12, 2000	1,140	Unscheduled Outage - NF Hydro
27	February 23, 2000	370	Test Run
28	March 28, 2000	400	Test Run
29	April 13, 2000	6,100	Unscheduled Outage - NF Hydro
30	June 28, 2000	6,720	Unscheduled Outage - NF Hydro

<b>Table 1</b> <b>Schedule of Usage of Portable Diesel Number 1</b>			
<b>No.</b>	<b>Date</b>	<b>Energy Generated (kWh)</b>	<b>Reason for Use</b>
31	August 23, 2000	1,280	Scheduled Run for NF Hydro
32	September 29, 2000	330	Test Run
33	October 27, 2000	330	Test Run
34	November 29, 2000	300	Test Run
35	December 19, 2000	360	Unscheduled Outage - NF Hydro
36	December 25, 2000	2,130	Unscheduled Outage - NF Hydro
37	February 22, 2001	360	Test Run
38	April 27, 2001	540	Test Run
39	July 27, 2001	430	Test Run
40	October 30, 2001	320	Test Run
41	November 2, 2001	2,960	Scheduled Run for NF Hydro
42	November 9, 2001	1,350	Scheduled Run for NF Hydro
43	December 6, 2001	240	Test Run
44	January 29, 2002	370	Test Run
45	February 27, 2002	480	Test Run
46	March 8, 2002	5,050	Moving Fuel Tank
47	April 23, 2002	600	Test Run
48	May 29, 2002	570	Test Run
49	August 22, 2002	280	Test Run
50	September 26, 2002	330	Test Run
51	October 2, 2002	1,060	Scheduled Run for NF Hydro
52	November 28, 2002	390	Test Run
53	December 16, 2002	400	Test Run
54	December 17, 2002	1,570	Unscheduled Outage - NF Hydro
55	December 20, 2002	1,500	Scheduled Run for NF Hydro

1  
2

1

<b>Table 2</b> <b>Portable Diesel Number 2</b> <b>Schedule of Usage</b>			
<b>No.</b>	<b>Date</b>	<b>Energy Generated (kWh)</b>	<b>Reason For Use</b>
1	January 28, 1998	350	Test Run
2	March 24, 1998	320	Test Run
3	April 21, 1998	280	Test Run
4	May 28, 1998	310	Test Run
5	June 12, 1998	1,020	Scheduled Run for NF Hydro
6	July 28, 1998	4,580	Scheduled Run for NF Hydro
7	July 29, 1998	1,020	Scheduled Run for NF Hydro
8	July 30, 1998	2,040	Scheduled Run for NF Hydro
9	August 28, 1998	270	Test Run
10	September 30, 1998	300	Test Run
11	March 31, 1999	520	Test Run
12	May 28, 1999	340	Test Run
13	July 27, 1999	4,600	Scheduled Run for NF Hydro
14	July 28, 1999	4,290	Scheduled Run for NF Hydro
15	July 29, 1999	4,290	Scheduled Run for NF Hydro
16	July 30, 1999	4,290	Scheduled Run for NF Hydro
17	August 31, 1999	770	Scheduled Run for NF Hydro
18	September 8, 1999	4,270	Scheduled Run for NF Hydro
19	October 22, 1999	1,870	Unscheduled Outage - NF Hydro
20	November 26, 1999	200	Test Run
21	December 29, 1999	380	Test Run
22	January 12, 2000	990	Unscheduled Outage - NF Hydro
23	February 23, 2000	310	Test Run
24	March 28, 2000	580	Test Run
25	April 13, 2000	4,420	Unscheduled Outage - NF Hydro
26	June 28, 2000	6,000	Unscheduled Outage - NF Hydro
27	August 23, 2000	740	Scheduled Run for NF Hydro
28	September 29, 2000	380	Test Run
29	October 27, 2000	210	Test Run
30	November 29, 2000	310	Test Run
31	December 19, 2000	280	Unscheduled Outage - NF Hydro
32	December 25, 2000	1,650	Unscheduled Outage - NF Hydro
33	February 22, 2001	230	Test Run
34	July 27, 2001	280	Test Run
35	October 30, 2001	250	Test Run
36	November 2, 2001	3,000	Scheduled Run for NF Hydro
37	November 9, 2001	1,370	Scheduled Run for NF Hydro
38	December 6, 2001	210	Test Run

<b>Table 2</b> <b>Portable Diesel Number 2</b> <b>Schedule of Usage</b>			
<b>No.</b>	<b>Date</b>	<b>Energy Generated (kWh)</b>	<b>Reason For Use</b>
39	January 29, 2002	270	Test Run
40	February 27, 2002	440	Test Run
41	April 23, 2002	440	Test Run
42	May 29, 2002	530	Test Run
43	August 22, 2002	300	Test Run
44	October 31, 2002	300	Test Run
45	November 28, 2002	460	Test Run
46	December 16, 2002	330	Test Run
47	December 17, 2002	1,420	Unscheduled Outage - NF Hydro
48	December 20, 2002	1,370	Scheduled Run for NF Hydro