

2.5 MW Standby Portable Diesel, Schedule B, pages 14-15 (\$1,700,000)

Q. Over the past 5 years, were the previous portable generators normally connected to the electrical system? If so, please indicate the periods for each.

A. Yes, the portable generators are always connected to the electrical system and ready to produce energy for the electrical grid when a requirement arises. The only exception would be when the generators are in transit from one location to another. Please refer to the Company's response to Request For Information NLH-24 for the actual times that the portable generators were producing energy for the electrical grid.