

1 **Rebuild Substations, Schedule B, pages 18-19 (\$1,023,000)**

2
3 **Q. Please provide cost breakdown details for the station and fuel storage extensions for**
4 **the Grand Bay Substation.**

5
6 A. Table 1 provides a detailed cost breakdown of the station extension for the Grand Bay
7 Substation. This project involves enlarging the substation to provide the proper
8 clearances for the new 2.5 MW portable diesel generator being acquired in 2003. A fuel
9 storage extension is not required for this project.

10

Table 1	
Detailed Cost Breakdown	
(000s)	
Cost Category	Cost
Material	\$92
Labour - Internal	14
Labour - Contract	-
Engineering	39
Other	-
Total	\$145

11