

1 **Replacement & Standby Substation Equipment, Schedule B, pages 20-21; Appendix 2,**
2 **pages 1-7 (\$1,314,000)**
3

4 **Q. Are the Corporate Spares and Replacements replacing existing spares? If they are,**
5 **please provide details of the spares to be retired.**
6

7 A. There are no spares being retired and replaced by equipment purchased under this
8 category.
9

10 Corporate Spares and Replacements replace existing spares that have been used to replace
11 field equipment that is no longer usable due to severe deterioration or failure. As an
12 example, when the breaker on transmission line 305L at Laurentian Substation (LAU-
13 305L-B) failed, it was replaced with a spare unit. As a result, a new spare breaker was
14 required to replace the spare unit that was removed from inventory.