

Distribution Feeder Remote Control, Schedule B, pages 26-27 (\$1,000,000)

Q. How many of the 25 distribution system feeder relays that are proposed to be replaced have remote control and indication at present?

A. None of the 25 distribution feeders have individual remote open/close control. Twenty of the feeders have a Group Close function. The Group Close function allows a number of feeders at a substation to be closed simultaneously. This function is not adequate at times when specific individual feeders are required to be operated without affecting other feeders. All 25 distribution feeders have remote indication.