Increase Corner Brook Transformer Capacity, Schedule B, pages 30-31 (\$1,894,000)

1 2 3

Q. Is the existing transformer a single rated unit? If so, have staged cooling options been studied?

4 5 6

7

8

A. No, the existing transformer is not a single rated unit. All the transformers serving the 12.5kV system in the City of Corner Brook have the maximum number of radiators and fans installed. Following are the ratings for each transformer showing the difference in the rating associated with the installation of additional radiators and fans.

9 10

11	WAL-T2	11.25 to 15.0 MVA
12	WAL-T1	15.0 to 20.0 MVA
13	HUM-T3	10.0 to 13.3 MVA
14	BVS-T1	15.0 to 20.0 MVA