

1 **Increase Corner Brook Transformer Capacity, Schedule B, pages 30-31 (\$1,894,000)**  
2 **[sic \$1,184,000]**

3

4 **Q. How is the relocation of the 15 MVA unit to Bayview justified against the**  
5 **availability of other spare transformers for the system?**

6

7 A. Newfoundland Power does not have spare power transformers of a size suitable for  
8 installation at Bayview. Due to limitations on the amount of load that can be transferred  
9 between Walbournes and Bayview Substations, it is necessary to install additional  
10 transformation at Bayview. The existing Walbournes T2 is a close impedance match for  
11 the existing Bayview-T1, which will allow operation of the both transformers in parallel.