

**Volume III, Distribution Lightning Arrestors, Appendix 2, Attachment B**

**Q. How long would it take before lightning arrestors were installed on 50%, 75% and 100% of NP's distribution transformers under normal transformer turnover?**

**A.** Under normal transformer replacements, it would take 12, 18 and 24 years to install lightning arresters on 50, 75 and 100% of NP's transformers respectively.