

Substations Appendix 2

Q. Does NP test oil filled electrical equipment to determine whether the PCB contamination is above the 50 ppm cut-off before slating the equipment for replacement.

A. Yes, the Company does perform a test to determine the PCB contamination level of electrical equipment before slating the equipment for replacement.