

**Reliability**

**Q. What are the company's existing reliability targets and those for 2005, 2006, 2007 and 2008 expressed as:**

- a) SAIDI**
- b) SAIFI, and**
- c) Up-time**
- for the following:**
- a) system wide**
- b) distribution**
- c) transmission,**
- d) feeders, and**
- e) substations**

**A. The Company's reliability targets for 2003 are a SAIDI of 4.75 and SAIFI of 4.56. The Company does not set up-time targets based on system wide, distribution, transmission, feeders or substations.**

The Company has not established reliability targets for the 2004 through 2008 period.